

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1599:105

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Ziton (Pty) Ltd., PO Box 4965, Capetown, South Africa 8000
Contact: Roger Airey 01127215066045 FAX 01127215066060

DESIGN: Model Z620U-622-2 combination fixed temperature/rate-of-rise and Model Z620U-621-2 fixed temperature heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC
Fixed temperature: Rated 135°F
Rate of Rise Temperature: Rated 15 °F/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, ratings, and UL label.

APPROVAL: Listed as heat detectors for use with Edwards System Technology's separately listed compatible fire alarm control units Models QSC, QS1, QS4 (CSFM Listing No. 7165-1591:207), EST1-2Z3, -2Z3R, -2Z6 (CSFM Listing No. 7165-1591:164), EST3 (CSFM Listing No. 7165-1591:186), and LSS4 (CSFM Listing No. 7165-1591:138); and listee's separately listed Model Z6U-BS1 base (CSFM Listing No. 7300-1599:103). Refer to listee's Installation Instruction Manual for details.

08-05-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 5, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**